



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY	
Received	11/9/09
Code	6.9-09

INSTRUCTIONS: Only TYPED copy accepted.
(KEY – Dashed line through material to be deleted, underline material to be added)
Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition	
Section number and title R202 Definitions		Page 1 of 1	
Proponent Craig Wagner		Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111	
PROPOSED CODE CHANGE (Check One)			
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution			
<p>Change the definition of “conditioned space” in Section R202 as follows:</p> <p>Chapter 2 Definitions – Conditioned Space. For energy purposes, space within a building that is provided with heating and/or cooling equipment or systems capable of maintaining, through design or heat loss/gain, 50°F (10°C) during the heating season and 85°F (29°C) during the cooling season, or communicates directly with a conditioned space. For mechanical purposes, an area, room or space being heated or cooled by any equipment or appliance. An area or room within a building being heated or cooled, containing uninsulated ducts, or with a fixed opening directly into an adjacent conditioned space.</p>			
REASON			
<p>This proposal changes the IRC definition of conditioned space to the same definition listed in the 2009 IECC, and is one of the recommended changes to bring the IRC into equivalence with the IECC.</p> <p>Fiscal impact: no increase to the cost of construction.</p>			
REVIEW RECOMMENDATION			
Approve			
Disapprove			
Approve as amended			
Further Study			